

Wind turbines

Fire protection guideline



This guideline is not binding. In individual cases the insurer reserves the right to agree on other safety precautions according to its risk evaluation, which may deviate from these technical specifications.

Source of the title sheet



HDI-Gerling

Allianz

Allianz

Hans-Werner Bastian

Wind turbines

Fire protection guideline

Inhalt

1	Preliminary notes	4
2	Scope of application	4
3	Risks	5
3.1	Damage to property and follow-up costs.....	5
3.2	Examples of damages.....	6
3.3	Causes of fire damage	8
4	Protection objectives and protection concept	9
5	Protection measures	11
5.1	Reducing the risks of an outbreak of fire	11
5.2	Fire detection and fire fighting.....	15
5.3	Measures for limiting loss.....	19
5.4	Quality assurance	19
6	Literature/Sources	20

1 Preliminary notes

With the politically declared objective to support renewable energy sources and to increase their share in the overall energy supply significantly, wind turbines have developed rapidly over the last few years. In addition to the expansion of locations, the development is characterized by a constant increase of wind turbines' dimensions (hub height, rotor diameter) and a constant performance increase to up to 6 MW at present (2007).

The concentration of values coming along with the performance increase at wind turbines, and increasing requirements with respect to the availability of wind turbines as well as loss experiences made over the last few years have caused

- the German Insurance Association (GDV) and
- Germanischer Lloyd Industrial Services GmbH, Business Segment Wind Energy (GL Wind)

to prepare the present guideline on fire protection for wind turbines.

This guideline will describe typical risks of fire given under the special conditions of the operation of wind turbines. Measures for loss prevention will be suggested as a result of the fire risk analysis. The objective is to minimize the incidence rate and the scope of a potential fire damage at wind turbines. In addition to special fire protection measures for detecting, fighting and preventing fires, procedural safety measures and comprehensive control technologies/systems for monitoring procedural operations and conditions are required. It must be ensured that the wind turbine is being transferred to a safe state as a result of early detection of malfunctions of the system.

The application of so-called Condition Monitoring Systems (CMS) is basically suitable for avoiding mechanical consequences of loss. Maintenance and controlling measures for wind turbines, including a possible shutdown required to avoid damage before it occurs, may be derived by means of monitoring the condition of relevant components and modules in the wind turbine and by documenting change processes. The following aspects have to be taken into account in order to ensure professional monitoring and condition-oriented reaction if required:

- Suitability of CMS for wind turbines with respect to the operating conditions to be expected
- Scope of the condition monitoring
- Indicators and measurement (sensors)

- Capturing, processing and forwarding of the signal
- Relevant limiting values
- Alarm and acknowledgement of the alarm
- Possible change of condition and its evaluation (diagnostics)
- Documentation (data storage) and its preparation for the purpose of evaluating changes of conditions (database)

Manufacturers of wind turbines and their components as well as operators of wind turbines are each responsible in their sphere of action.

Condition monitoring systems do not replace the required maintenance of wind turbines (see also paragraph 5.1.6)

The information on safety measures described in the following paragraphs neither claims to be complete nor does it release anyone from the adherence to official obligations and regulations.

The present publication is based on the loss experiences that are currently available and on prospective safety-related failure analyses.

In case that there will be any basic alterations with respect to the risk-related evaluation, it is intended to update this guideline.

Adherence to legal regulations and relevant sets of rules representing state-of-the-art safety technology is being implied.

2 Scope of application

The present guideline refers to the planning and operation of wind turbines constructed as lattice mast or tower.

The fire protection concept applies to individual wind turbines as well as to wind farms designed as onshore or offshore installations.

Fire protection requirements on wind turbines refer to the overall system and take into account the system-specific main areas of risk at the rotor blades, in the nacelle (machine house), in the tower, or at the premises.

Depending on the kind of risk, different fire protection measures might be required.

Fire protection measures are specifically designed for the operation and for servicing and maintenance activities resulting from the operational process. All fire protection measures should be ready for operation by the time the operation starts at the latest.

Fire protection measures mentioned in this guideline do not take into account the assembly period.

This guideline basically applies to turbines that will be newly built. Existing turbines should be adjusted to the fire protection measures mentioned in this guideline as far as is feasible.

3 Risks

Wind turbines differ from traditional power generation systems in terms of the basically existing risk of total loss of the nacelle as a result of initial fire. Main features of risk include:

- High concentration of values within the nacelle
- Concentration of potential ignition sources within the nacelle, and increased risk of lightning strikes
- Unmanned operation
- No possibility of fighting the fire by fire brigades because it is too high
- Remote, sometimes difficult to reach locations of the wind turbines, which is the case with offshore installations in particular

The average newly installed capacity per wind turbine has increased continuously in the last few years.

Year	Average capacity per newly installed wind turbine [kW]	Number of total turbines [unit]
2002	1395	13759
2003	1553	15387
2004	1696	16543
2005	1723	17574
2006	1849	18685

Source: DEWI (German Wind Energy Institute)

Table 1: Wind turbines in Germany

The expenses for wind turbines and their components as well as the restoration costs after a fire increase with the increase of the installed capacity. In addition, the loss caused by an interruption of operations increases with increasing capacity.

3.1 Damage to property and follow-up costs

According to the insurers' loss experience, fires at wind turbines can cause significant damage to property and very high follow-up costs – as shown in the following examples – amongst others due to the downtime of the wind turbine and liability claims, etc.

3.1.1 Property risk

Fire damage in wind turbines may occur

- in the nacelle,
- in the tower,
- in the electric power substation of the wind turbine or the wind farm.

Today, in most new wind turbines,

- switchgear, inverter, control cabinets and
- transformer

are placed in the nacelle. Thus, the risk of fire increases significantly there. Due to the high density of technical equipment and combustible material in the nacelle, fire can spread rapidly. Moreover, there is the danger that the upper tower segment is being damaged in addition. In case of a total loss of the nacelle, the restoration costs may well reach the original value of the wind turbine.

With respect to offshore wind turbines, significantly higher costs for required special ships, e.g., floating cranes or cable layers are to be expected. In the case of partial loss, in particular, this can significantly increase the overall loss expenses.

3.1.2 Exposure to interruption of operations

Experience has shown that in case wind turbines are damaged, interruptions of operations usually take some time. Interruptions of several months are not unusual. In case of total damage to the nacelle, the time of interruption of operations may well last 9 to 12 months. Components with the longest delivery time include, amongst others, gearbox, generators, and transformers. In case of damages to offshore wind turbines, the dependency on the weather when trying to reach the turbines and the dependency on the availability of a crane/service ship cause additional difficulties.

If the damage is so severe that it would be sensible from an economic point of view to rebuild the

turbine, the operator is subject to official obligations. The notice of approval for erecting a wind turbine usually specifies the type of the wind turbine. The operator does not have any possibility to erect a modified turbine at the site of the damaged wind turbine if

- the notice of approval does not apply any longer or
- there is no approval for repowering.

In both cases a new approval procedure is necessary, which might extend the time of interruption of operations.

If a wind turbine has an installed capacity of 2 MW and an average annual output of 4 million kWh as well as a supposed maturity of 20 years, the loss of feed-in tariff according to the German Renewable Energy Sources Act (EEG) amounts to approximately EUR 5,000 per week, for example. (BWE Market Survey 2006, German WindEnergy Association)

If a wind farm's central electric power substation is damaged by fire, all connected plants are disconnected from the public power supply system at the same time. The loss of profits increases proportionally with the number of connected wind turbines. Central electric power substations of offshore wind farms represent a particularly high risk of interruption of operations since they

- comprise a large number of individual turbines each,
- are particularly efficient, which usually results in longer delivery times in case replacements are required, and
- might be difficult or impossible to reach at some times and depend on the availability of crane/service ships, like offshore wind turbines.

3.2 Examples of damages

3.2.1 Fire damage caused by lightning strike

During a heavy summer thunderstorm, the blade of a 2 MW wind turbine was struck by lightning. The turbine was shut down automatically and the blades were pitched out of the wind.

The burning blade stopped at an upright position and burned off completely little by little. Burning parts of the blades that fell down caused a secondary fire in the nacelle.

Investigation of the cause of damage showed that the fire in the blade was caused by a bolted



Fig. 1: Fire after lightning struck a 2 MW wind turbine in 2004 (Image source: HDI/Gerling)

connection of the lightning protection system that was not correctly fixed. The electric arc between the arrester cable and the connection point led to fusion at the cable lug and to the ignition of residues of hydraulic oil in the rotor blades.

The nacelle, including the rotor blades, had to be referred to as a total loss. The upper part of the tower had also been destroyed due to the high temperature.

Operations were interrupted for approximately 150 days; the total loss amounted to approximately EUR 2 million.

Deficient lightning arrester installations in the rotor blades of wind turbines have already caused several damages by fire in the past.

3.2.2 Fire damage caused by machinery breakdown

The nacelle of a 1.5 MW wind turbine completely burned out after the slip ring fan of the doubled induction generator had broken. Sparks that were generated by the rotating fan impeller first set the filter pad of the filter cabinet on fire and then the hood insulation. The damage to property amounted to EUR 800,000.



Fig. 2: Burnt down nacelle of a 1.5 MW wind turbine
(Image source: Allianz)

3.2.3 Fire damage caused by failure in electrical installations

A low-voltage switchgear was installed within the nacelle of a 1 MW wind turbine. The bolted connection at one of the input contacts of the low-voltage power switch was not sufficiently tightened. The high contact resistance resulted in a significant temperature increase at the junction and in the ignition of adjacent combustible material in the switchgear cabinet. The fuses situated in front did not respond until the thermal damages by the fire were very severe. Control, inverter and switchgear cabinets that were arranged next to each other suffered a total loss. The interior of the nacelle was full of soot. Despite the enormous heat in the area of the seat of fire, the fire was unable to spread across the metal nacelle casing. The damage to property amounted to EUR 500,000.



Fig. 3: Power switch of a 1 MW wind turbine – destroyed by fire (Image source: Allianz)

3.2.4 Fire damage caused by resonant circuits

Several damages were caused by parallel resonant circuits consisting of capacities (reactive power compensation or line filters) and inductances (generator, turbine transformer, energy supply companies, power chokes, etc.) which had not been taken into account when designing the turbine. The resonant circuits were activated by harmonics. Resonance phenomena generated high currents which damaged capacitors. Breakdowns in the dielectric of the already damaged capacitors – usually caused by overvoltage events – resulted in an increase of power loss and in some cases in the bursting of the capacitor containers. The resulting fires usually caused total loss to the reactive power compensation or to the inverter. Protective circuits through discharge resistors and choking were not available in the respective cases.



Fig. 4: Burst pressure vessel of a line filter capacitor
(Image source: Allianz)

3.3 Causes of fire damage

Based on loss experiences of insurers, the following paragraphs will provide an overview of typical causes of an outbreak and spread of fire.

The causes of fire damages are basically the same with offshore wind turbines and with onshore wind turbines. However, due to stronger exposure to environmental conditions and currently still quite limited experiences, the probability of technical defects and thus the risk of fire are probably higher with offshore wind turbines than with onshore wind turbines.

3.3.1 Increased risk of an outbreak of fire caused by lightning strike

A large number of cases of damage have shown that lightning strikes are among the most frequent causes of fire at wind turbines.

The special risk of lightning strikes arises from the exposed locations (often located at a higher altitude) and the large height of the structure, amongst others.

The risk of fire increases particularly when the lightning protection system is not implemented and maintained properly. If the contact resistance of the lightning conductor path is too high, thermal damages are almost inevitable in case of lightning strikes.

3.3.2 Electrical installations

Besides lightning strikes, failures in electrical installations of wind turbines are among the most common causes of fire. Fire is caused by overheating following overloading, earth fault/short circuit as well as arcs. Typical failures include the following:

- Technical defects or components in the power electronics (e.g., switchgear cabinet, inverter cabinet, transformer) that have the wrong dimension
- Failure of power switches
- Failure of control electronics
- High contact resistance due to insufficient contacts with electrical connections, e.g., with bolted connections at contact bars
- Insufficient electrical protection concept with respect to the identification of insulation defects and the selectivity of switch-off units
- No or no all-pole disconnection of the generator in case of failure/switch-off of the turbine
- Missing surge protection at the mean voltage side of the transformer
- Resonances within RC (resistor-capacitor) circuits (line filter, reactive power compensations)

3.3.3 Hot surfaces

If all aerodynamical brakes fail, mechanical brakes, which shall slow down the rotor, can reach temperatures that result in an ignition of combustible material. In case of such an emergency braking, flying sparks that are caused by mechanical brakes without cover also pose a high risk since flying sparks might also ignite combustible material that is further away. Defects at turbines or parts thereof, e.g., leakage of the oil systems and dirt, increase the risk of fire.

Other risks exist in case of overloading and poor lubrication of generator and gearbox mountings. In these cases the mountings get too hot. Combustible material and lubricants can ignite when they get in contact with hot surfaces. For example, if a failure at the mounting leads to rubbing of rotating components, the flying sparks resulting thereof might cause a fire.

3.3.4 Work involving fire hazards

Work involving fire hazards relating to repair, assembling and disassembling work, e.g., welding, abrasive cutting, soldering and flame cutting, is a frequent cause of fire. Due to the high temperatures that occur during these activities, combustible material that is in the close or further environ-

ment of the working site may get on fire. Welding, cutting and grinding sparks are particularly dangerous since they can ignite combustible material that is at a distance of 10 metres and more from the working site. Many fires break out several hours after the completion of work involving fire hazards.

3.3.5 Fire load

A wide variety of combustible material that can cause an outbreak of fire and result in a fast spread of fire is being applied in the nacelle of wind turbines, e.g.,

- internal foam sound insulation of the nacelle, in parts contaminated by oil-containing deposits,
- plastic housing of the nacelle (e.g., GRP),
- oil in the hydraulic systems, e.g., for pitch adjustments, braking systems. If there are any damages or if the temperature is very high, high pressure in the hydraulic pipes can cause the hydraulic oil to escape finely nebulized, and this can cause an explosive spread of the fire,
- gearbox oil and other lubricants, e.g., for the generator bearings,
- transformer oil,
- electrical installations, cables, etc.

Hydraulic oils, oil-containing waste that has not been removed, and lubricants, which are stored in the nacelle are additional fire loads and not only increase the general risk of fire unnecessarily, but also increase the risk of a spread of fire, in particular.

3.3.6 Strongly limited accessibility for fire fighting

With the currently available means, fire brigades do not have any chance to fight fires at wind turbines if the nacelle or rotors are affected. The fire brigade's turntable ladder does not reach the necessary height. Therefore, a nacelle that is on fire cannot be reached from the outside. The way towards the nacelle via ladder or elevator of a burning turbine is also perilous for fire fighters, and therefore, this is also no option. Fire fighters are exposed to the risk of getting hurt by burning parts falling down even on the ground at the surroundings of the turbine. Due to the fact that there is an increasing trend to integrate transformers into the nacelle, fire fighters also have to pay attention to high-voltage power lines.

With respect to the fires that have occurred so far, the fire fighters' work has been restricted to the protection of the location of the fire and the prevention of secondary fires on the ground or at adjacent installations.

In case offshore wind turbines are affected by fire, manual fire fighting from the outside is not to be expected.

3.3.7 Limitations with respect to maintenance (servicing, inspection and repair)

Due to the cramped confines in wind turbines and the limited accessibility of the turbines' components it is very difficult for the maintenance staff to conduct maintenance work appropriately and professionally. The quality of work might suffer from the difficult conditions.

4 Protection objectives and protection concept

Fire precautions for wind turbines, which are described in detail in this guideline, shall supplement existing regulations and aim at minimizing damage to property through limitation of the risks of an outbreak of fire and spread of fire on the one hand, and at preventing interruption of operations due to fire on the other hand, and thus ensuring the availability of the wind turbines.

The required scope of protection for wind turbines may vary depending on the object-specific risk and the risks to be insured, which can also significantly determine the insurability according to the insurers' experience.

Experience has shown that in order to ensure the required fire safety it is always sensible to prepare a fire protection concept after consulting with all parties involved, the insurer in particular. According to this concept, all structural, turbine-specific and organizational protection measures shall supplement each other in terms of risk and protection targets, and any kind of mutual impairment of protection functions shall be excluded. The risks of an outbreak of fire shall be limited effectively by the following, amongst others:

- Use of non-combustible or difficult to ignite materials
- Early fire detection with automatic fire detection/ alarm systems
- Frequent as well as professional maintenance

- Automatic switch-off of the turbines and complete disconnection from the power supply system in case risks are being identified
- Training of employees with respect to handling dangerous situations, and in-house regulations with respect to work involving fire hazards, e.g., welding permit procedure.

In order to limit the risks of fire spread,

- early fire detection with automatic fire detection/alarm systems and
- fire fighting with automatic fire extinguishing systems

have proven to be effective in addition to the use of fire resistant components.

Moreover, it is always helpful to prepare an emergency plan in order to limit potential damages, and to keep this plan updated. Implementation of this plan should be ensured by means of trainings that take place on a regular basis.

Highly acknowledged rules of technology have been prepared for planning, implementation and operation of these fire precautions as well as for assuring their quality. The present guideline will refer to these rules.

In addition, changes of the conditions in the power train can be detected early on by means of condition monitoring systems (CMS), and thus the risk of an outbreak of fire due to such changes can be prevented.

Reference: GL guideline for the certification of condition monitoring systems for wind turbines

In case existing wind turbines shall be revised in terms of fire protection according to this guideline, it should be clarified in advance with authorities, the manufacturer of the turbine, the certifying body of the turbine, and the insurer, amongst others, whether a renewal of the official approval and certification of the turbines might be required due to retrofitting.

It is generally sensible to grade the required scope of protection depending on the risk parameters. In doing so, the following has to be taken into account, e.g.,

- loss experiences with different types and components of turbines,
- capacity of the turbine in MW,
- structure of the wind turbine and arrangement of risk components,

- location of the turbine (onshore or offshore),
- amount insured, and
- amount of deductible.

Table 2 shows an example of the grading of protection measures by means of so-called protection levels. It is possible to agree upon a different grading of protection measures after consulting with the insurer. Lightning and surge protection according to paragraph 5.1.1 as well as general electrical protection measures according to paragraph 5.1.2 are generally implied.

Moreover, in case the automatic early fire detection system which serves to monitor the installation and room is activated, the wind turbine shall be automatically shut down and disconnected completely from the power supply system.

Protection measures as modules	Protection levels			
	0	1	2	3
Fire detection system – installation and room monitoring	x	x	x	x
Fire extinguishing systems – installation protection				
Control, inverter and switch-gear cabinets (LV/MV)		x	x	x
Transformer			x	x
Hydraulic system				x
Slip ring housing of the generator				x
Fire extinguishing systems – room protection				
Raised floors with oil sump and cable and electrical installation			x	x
Nacelle with generator, transformer, hydraulic systems, gearbox, brake, azimuth drive				x
Hub with pitch drive and generator, if applicable				x
Tower base/platform with existing installations, if applicable				x

Table 2: Examples of protection levels

Evidence of the effectiveness and reliability of turbine-specific fire precautions can be provided through respective approval of components and systems by *VdS Schadenverhütung* or through similar approval.

The overall fire protection concept for wind turbines shall be checked by an independent, acknowledged body after consultation with the insurer, if applicable, with respect to whether an

adequate protection against risk is ensured for the respective wind turbine. This can be done in the course of a test and certification procedure complementing the type testing and certifications by, e.g., Germanischer Lloyd Industrial Services GmbH, that have proven their value and that might be required.

Reference: GL Wind Guideline, certification of fire protection systems for wind turbines, test procedure

5 Protection measures

The following explanations represent an instruction for specifying fire precautions in the framework of a turbine-specific fire protection concept.

5.1 Reducing the risks of an outbreak of fire

Potential risks of fire and explosions should already be identified and important aspects of fire protection should already be taken into account during the planning and construction phase.

5.1.1 Lightning and surge protection

Wind turbines have to be equipped with comprehensive lightning and surge protection that is adjusted to the individual type of turbine. Systems for lightning and surge protection have to be planned, build and operated like other components of the wind turbine according to the acknowledged rules of technology.

In order to plan systems for the purpose of lightning and surge protection it is required to do a risk evaluation or to assume the highest possible risk according to IEC 62305 (lightning protection level I = LPL I). When evaluating the risk, the possible lightning paths, e.g., from the rotor blade via hub, nacelle and tower to the foundation, have to be recorded and observed exactly.

Lightning and surge protection have to cover the nacelle and rotor blades, in particular, as well as any kind of electrical installations or equipment, including cable lines that are relevant for operation and safety.




Fig. 5: Allocation of lightning protection zones (BSZ) at wind turbines with metal nacelle (Source: Phoenix Contact)

Attention has to be paid to the allocation of the wind turbines' components to individual lightning protection zones depending on the disturbance variable through partial lightning currents and switching surges that may be expected.

In order to design the turbines' components for lightning protection, the relevant protection level of the turbines has to be defined. In doing so, at least protection level II should be chosen for a comprehensive lightning protection system for wind turbines.

However, as is the case with high towers, low-voltage lightning strikes also pose a challenge to wind turbines. Therefore, protection areas at the tower, nacelle, hub and rotors – also rotating – should be identified by means of the so-called rolling sphere method.

Reference:

- VdS 2010: *Risk-oriented lightning and surge protection; guidelines on loss prevention*
- DIN EN 61400 (VDE 0127): *Wind turbines – Part 1: Design requirements (IEC 61400-1)*
- DIN EN 62305 (VDE 0185-305) *Protection against lightning*
- *Part 1: General principles (DIN EN 62305-1; VDE 0185-305-1)*
- *Part 2: Risk management (VDE 0185-305-2) including supplementary sheets 1 and 2*
- *Part 3: Physical damage to structures and life hazard (DIN EN 62305-3 und VDE 0185-305-3) including supplementary sheets 1 to 3*

- *Part 4: Electrical and electronic systems within structures (IEC 62305-4)*
- *Guideline for the certification of wind turbines: 8 Electrical systems; section 7: Lightning protection measures, Germanischer Lloyd Industrial Services GmbH*

5.1.2 Minimizing the risk of electrical systems

The protection technology, which comprises any electrical installations as well as measures for identifying power system faults and other abnormal operating conditions at wind turbines and the associated peripheral systems, shall be state of the art. Its main task is to identify flaws selectively and to switch off faulty parts of the power system or individual electrical equipment, e.g., transformer, line, generator, immediately. There is currently no sufficient protection in most of the older wind turbines.

Graded protection concepts which create mutual reserve protection through the integration of the protection systems of adjacent equipment provide the best possible protection against fire. This applies to the overall system planned by the plant's manufacturer and the wind farm developer and to components which the planner creates on his own according to the plant manufacturer's requirements. For example, with the appropriate configuration, the risk of fire arising from an arc in a low-voltage switchgear can be prevented despite failure of the power switch. Appropriate arcing fault protection systems detect the fault and open the medium-voltage switch at the transformer's high-voltage side. Thus, the faulty component is being selectively disconnected from the power system. The same goes for high-resistance earth faults which emerge between low-voltage power switch and transformer.

The protection systems have to ensure immediate, controlled shutdown of the wind turbine with subsequent all-pole (medium-voltage side) disconnection from the power system. The activating of protection systems shall result in sending a fault message to the remote control.

Reference:

- *VdS 2025: Cable and line systems, guidelines on damage prevention*
- *VdS 2046: Safety regulations for electrical systems up to 1000 volt*
- *VdS 2349: Electrical installations with minimal interferences*

5.1.3 Minimizing combustible material

Hydraulic and lubricant oils should be chosen according to the following characteristics: in addition to their technical features required, they should preferably be non-combustible or have a high flash point which is significantly above the operating temperatures of the systems.

The application of combustible material, e.g., foamed plastics such as PUR (polyurethane) or PS (polystyrene) as insulating material or GRP (glass-reinforced plastics) for coverings and other components should preferably be avoided for fire protection reasons.

If the application of non-combustible material is impossible in individual cases, the material used should at least be of low flammability (building material class DIN 4102-B1). Moreover, closed-cell material with washable surface should be used in order to avoid intrusion of impurities, oil leakage, etc., which otherwise would increase the risk of fire in the course of the operating time.

Cables and lines should be used that preferably

- separate slightly poisonous and corrosive decomposition products,
- do not cause much smoke and cause only little pollution of the rooms and content,
- do not support fire spread

when they burn.

When working with components that contain flammable liquids or oils, it must be made sure that leaking fluids are collected safely, e.g., by installing trays or by applying non-combustible oil binding agents. Leakages are to be removed immediately.

After the work has been completed, the collected fluids should be disposed properly, and impurified oil binding agents should be removed from the system.

Combustible material as well as auxiliary material and operating material should not be stored within the wind turbine.

5.1.4 Avoidance of possible ignition sources

Possible ignition sources include, e.g.:

- Lightning current
- Flying sparks occurring during the brake application of a mechanical brake

- Short circuit and arc as well as resonant circuits with electrical devices and systems
- Hot surfaces, e.g., bearings, brake disk
- Spontaneous ignition through dirty cleaning cloth (e.g., oil, solvents)

Components and possible ignition sources must be arranged and executed in a way that combustible material is not set on fire during normal operation or in case of malfunctions. In order to ensure this it might be necessary to install coverings, baffle plates or the like that are made of non-combustible material.

Electrical equipments should be secluded if possible.

Dirty cleaning cloths must be disposed when leaving the wind turbine.

5.1.5 Work involving fire hazards

Work involving fire hazards relating to repair, assembling or disassembling work should be avoided. If this is impossible it should be checked whether so-called cold procedures (sawing, screwing, cold bonding, etc.) can be used instead.

If work involving fire hazards cannot be avoided it is indispensable to take fire precautions prior, during and after the work in order to avoid an outbreak of fire or to detect a fire early on, and to fight it effectively.

Reference:

- *VdS 2008 Work involving fire hazards – guidelines for fire protection*
- *VdS 2036 Permit for welding, cutting, soldering, thawing and abrasive cutting (sample)*
- *VdS 2047 Safety regulations for work involving fire hazards*

5.1.6 Maintenance (servicing, inspection and repair) of mechanical and electrical systems

Fire caused by technical defects at electrical and mechanical systems represent the most frequent causes of damages. Means to reduce such kind of damage include regular maintenance according to the manufacturer's instructions (maintenance manual) and inspections of the systems as well as timely repair of identified deficiencies.

Tools serving this purpose, which are already available at many wind turbines, are systems that automatically monitor important operating

parameters such as pressure and temperature at mechanical and electrical systems such as transformer, generator winding, gearboxes, hydraulic systems or bearings. If the limiting value is exceeded or is not reached, there should be some kind of alarm and finally an automatic shutdown of the wind turbine. In the course of type testing and certification processes of wind turbines, the monitoring of operating parameters is usually taken into account.

Electrical installations and monitoring systems in wind turbines have to be examined by experts on site on a regular basis. At least every five years the gas and oil of the transformer insulation liquid have to be analyzed, amongst others.

The analysis allows drawing a conclusion on the quality of the insulating oil and provides information about possible electrical defects, thermal overloads of the transformer, and the condition of the paper dielectric. If there are any defects in the active component of oil transformers, there is the risk of an explosion due to large electrical currents in connection with the insulating oil as fire load resulting from rapidly increasing internal pressure in the boiler. With respect to dry-type transformers, the surface has to be controlled annually, and it has to be cleaned if necessary. Additional safety is provided by installations that serve the optical detection of partial discharge (spark switch).

Recurring inspections of electrical installations according to VdS 2871 should usually take place every two years.

Reference:

- *VdS 2871 Testing guidelines according to clause 3602, guidelines for inspecting electrical installations*
- *DIN EN 50308 (VDE 0127-100) Wind turbines – Protective measures – Requirements for design, operation and maintenance*
- *DIN EN 50110-100 (VDE 0105-100) Operation of electrical installations*
- *DIN EN 60204-1 (VDE 0113-1) Safety of machinery – Electrical equipment of machines – Part 1: General requirements*
- *DIN EN 60599 (VDE 0370-7, IEC 60599) Mineral oil-impregnated electrical equipment in service – Guide to the interpretation of dissolved and free gases analysis*
- *DIN EN 61400-2 (VDE 0127-2) Wind turbines – Part 2: Safety of small wind turbines (IEC 61400-2)*

- *Accident prevention regulation: Electrical installations and equipment (BGV A 3, formerly VBG 4)*

In addition to these inspections, thermography at the electrical installations should be examined on a regular basis, e.g., in the following areas:

- Connection areas and, if possible, contacts of the LV HRC fuse switch disconnectors
- Clamping devices and terminal strips, respectively, in distribution boards as well as in switch terminal blocks and control terminal blocks
- Connection areas and, if possible, contacts of bus bars, contactors, capacitors, etc.
- Connection areas and surfaces of transformers, converters, and engines
- Power cable and cable bundles, respectively
- Surfaces of equipment which may pose a risk in case of heating.

Thermography inspections should be conducted by an approved expert who disposes of the technical qualification and the required measuring instruments, e.g., VdS-approved expert for electrical thermography.

Reference:

- *VdS 2858 Thermography in electrical installations*
- *VdS 2861 VdS-approved experts for electrical thermography, see also www.vds.de*

Mobile devices which are applied in the course of maintenance and repair have to be inspected on a regular basis according to BGV A3 (recommended period: semi-annually; maximum period: annually).

Lightning protection systems have to be inspected by an approved expert at regular intervals (annually). The inspection of the operability and condition of the lightning protection system includes a visual inspection of all air terminals and down conductors as well as measuring the contact resistance of the conduction path from the air terminals in the rotor blades to the ground terminal lug, and measuring the ground resistance of the foundation.

Reference:

- *VdS 3432 VdS-approved experts for lightning and surge protection as well as EMC-suitable electrical installations (EMC¹ experts)*

¹EMC = electromagnetic compatibility

- *Work rule "Inspection of the condition of the lightning protection system of wind turbines", German WindEnergy Association (BWE) (version: October 2004)*

The ground resistance of the foundation according to VDE 0185-305-3 (EN 62305-3) has to be measured in addition in the course of this recurring inspection.

The result of any maintenance activities should be documented in written form, e.g., in a maintenance specification sheet or a report book. Deficiencies that have been identified during maintenance or testing should be fixed immediately. The correction of deficiencies has to be documented and reviewed.

5.1.7 No smoking

The entire area of the wind turbine should be declared a non-smoking area.

In order to ensure compliance with the ban on smoking, employees and external companies, if applicable, should be instructed accordingly, and sanctions should be imposed in case of violation of the ban.

"No Smoking" signs have to be put up clearly and permanently right at the entry areas of the wind turbine.

5.1.8 Training

Service staff and authorized external companies, if applicable, are to be instructed on the risks of fire at the wind turbine on a regular basis. Instructions may include, amongst others:

- Preventing risks of fire
- Functionality of fire protection systems and installations installed as well as how to handle them
- Correct behaviour in case of fire, e.g., alerting assisting bodies
- Correct use of fire extinguishers

It is recommended to conduct fire protection trainings, e.g., test alarm, implementation of the emergency plan and evacuation of the nacelle, at regular intervals, and to involve the local fire brigade into these trainings.

5.2 Fire detection and fire fighting

Operating conditions, first of all environmental and weather conditions, for fire protection systems at wind turbines may vary significantly.

The following, in particular, has to be taken into account, e.g.,

- effects of atmospheres containing salt (offshore wind turbines),
- significant fluctuations of temperature due to the change of day and night, e.g., cooling down significantly at night and intensive sun shining at day,
- vibrations,
- oil deposits,
- air change and flow conditions in the nacelle.

Moreover, increased humidity, e.g., due to the location, and construction of the wind turbine may have an impact on the functionality of the turbine's technology.

Therefore, effects that may have an impact on the effectiveness and reliability of the fire protection technology have to be taken into account already in the planning phase of the turbine, and they have to be adjusted to the different techniques and constructions applied at wind turbines.

5.2.1 Fire detection

In order to effectively limit fire and consequential loss, fires at wind turbines should also be detected early on by automatic fire detection systems, in particular, since wind turbines are usually operated without any on-site staff. Distinction is basically made between room and installation monitoring.

On the one hand, automatic fire detection serves to inform the control unit, and on the other hand, it serves to activate the extinguishing devices automatically and to shut down the wind turbine automatically, if necessary.

Room monitoring

Nacelle and parts of the tower in which the wind turbine technology is installed as well as external transformer and electric power substations are to be monitored by an automatic fire detection system.

Raised floors and ceiling voids or the like with fire loads, e.g., cables and other lines, have to be included in the monitoring.

Reference: VdS 2095 Guidelines for automatic fire detection and fire alarm systems – planning and installation

Fire detectors have to be qualified for the area to be monitored and for the fire characteristics to be expected. Special environmental conditions, e.g., temperature, humidity, and vibrations, have to be taken into account when selecting and operating fire detectors; detector heating may be applied, if applicable. Fire detectors with the characteristic "smoke" should preferably be applied for the monitoring in wind turbines.

Installation monitoring

Applications which are operated, e.g.,

- encapsulated,
- forced-air-cooled and
- in rooms with high air change rate,

e.g., switchgear and inverter cabinets, require monitoring of installations in addition to the monitoring of rooms. "Smoke" should preferably be used as fire characteristic also with the monitoring of installations.

Reference: VdS 2304 Local application protection for electric and electronic equipment – Guidelines for planning and installation

The fire detectors' qualification is to be reviewed for each individual turbine depending on the respective operating conditions at the wind turbine and after consulting with the system's owner (manufacturer). Attention is to be paid to optimal fire detection and limitation of false alarms or nuisance alarms, in particular.

Mineral oil transformers should be protected with Buchholz relay (pre-alarm and main alarm with shutdown) in addition to room monitoring fire detection and temperature monitoring.

Automatic early fire detection only makes sense if at least the following reactions are triggered in case of activation:

- Fire alarm with alarm signal being forwarded to a continuously manned post
- Shutdown of the wind turbine and complete disconnection from the power supply system
- Activation of the installation and room protection extinguishing system with two-detector dependency (type B)

Detection systems that allow different alarm thresholds offer the possibility to induce gradual reactions depending on the alarm thresholds, e.g., pre-alarm, main alarm, etc.

When selecting a fire detection system it is important to pay attention to the fact that the maintenance required can be ensured in a feasible way given the location and the little space in the nacelle.

5.2.2 Fire fighting

Due to the fact that wind turbines are usually operated without any on-site staff and due to the time-consuming accessibility (in case of offshore wind turbines, in particular) and the strongly limited accessibility for fire fighters, effective fire fighting and thus limitation of loss can be ensured by automatic fire extinguishing systems, in particular, as has been shown in the past.

Fire extinguishing systems

For the purpose of effective fire protection of wind turbines, the use of automatic, stationary fire extinguishing systems is recommended. Gas extinguishing systems as well as fine water spray systems are basically suitable (taking into account the special conditions given). These fire extinguishing systems can be used as installation or room protection systems or as a combination of both. Installation protection systems have a selective effect on the device or component to be protected.

Before the fire extinguishing system is activated, the air-conditioning or ventilation system should be switched off automatically.

With respect to the application at wind turbines, extinguishing agents that are as residue-free, non-corrosive and non-electroconductive as pos-

Type of detector	Smoke detector			Heat detector (index "R" according to DIN EN 54-5)		Flame detector		Multi-sensor smoke detector	
	Point-shaped	Multi-point-shaped	Linear	Point-shaped	Linear	IR	UV	Smoke and heat	Smoke and CO
	Scattered light	Aspirating	Light beam						
Room/Installation									
Nacelle with transformer, including hub and raised floors	-	+	-	-	-	-	-	-	-
Central electric power substation, switch cabinet rooms	+	+	+	+	+	-	-	+	+
Tower base/platform with available installations, if applicable	-	+	-	+	-	-	-	-	-
Switchgear cabinets	+	+	-	-	-	-	-	+	-
Hydraulic systems	-	+	-	+	-	-	-	-	-
Transformer	-	+	-	Buchholz relay		-	-	-	-
+ basically suitable - not likely suitable The data in this table refers to the basic suitability of several types of detectors with respect to functionality and general application conditions in the respective area of the wind turbine's system; it serves as orientation guide and does not replace the required proof of suitability as well as the object-specific technical planning by appropriate specialist planners, e.g., VdS-approved installers. Type-specific characteristics of wind turbines and fire detection systems have to be taken into account after consulting with the insurer (e.g., Engineering department), VdS Schadenverhütung GmbH (VdS loss prevention) as well as the certifying body for wind turbines, if applicable (for more information see also VdS guidelines for the planning and installation of fire detection systems).									

Table 3: Information on the selection of fire detectors for monitoring rooms and installations

sible, and which are suitable with respect to the prevalent environmental conditions at wind turbines (temperature, weather, impermeability of the installations and rooms to be protected) and the fire loads would be desirable. The following systems can be applied at wind turbines, depending on the intended type of application:

- CO₂ fire extinguishing systems
- Inert gas extinguishing systems
- Fine water spray systems
- Water spray systems (transformer and electric power substation, respectively).

Powder extinguishing systems as well as aerosol extinguishing systems cannot be recommended for application at wind turbines since they may cause consequential loss.

Suitability of automatic fire extinguishing systems for the purpose of room and installation protection is basically to be reviewed for each individual turbine by taking into account the respective operating conditions at the wind turbine and by consulting with the manufacturer. The following aspects, in particular, have to be taken into account:

- Effectiveness of extinguishing
 - Required extinguishing gas concentration and impingement of water, respectively
 - Application (residence) time for gas extinguishing systems (taking into account possible reignition)
 - Operating time of water extinguishing systems (taking into account an effective extinguishing success)
 - Impermeability of the room/pressure relief
- Storing of extinguishing agents (required quantity, weight, etc.)
- Volume/Required space
- Installation/Approval, implementation
- Maintenance
- Reliability (robustness of the systems with respect to susceptibility to failure in order to limit maintenance and inspection intervals)
- Cost

In order to ensure the effectiveness of gas extinguishing systems it is necessary to pay special attention to the planning requirements in connection with the pressure relief openings that will have to be provided.

Moreover, attention should be paid to the required protection regulations with respect to the safety of persons when applying gas extinguishing systems.

Each extinguishing system has certain limits of applicability or advantages and disadvantages, respectively. Therefore, the suitability of the chosen extinguishing system has to be reviewed for each individual application because of the large number of possible parameters and the given conditions that are to be adhered to in order to ensure the effectiveness of extinguishing.

Reference:

- *VdS 2093 CO₂ fire extinguishing systems, guidelines for planning and installation*
- *VdS 2108 Foam extinguishing systems; guidelines for planning and installation*
- *VdS 2109 Water spray systems; guidelines for planning and installation*
- *VdS 2304 Local application protection for electric and electronic equipment; guidelines for planning and installation*
- *VdS 2380 Planning and installation of fire extinguishing systems using non-liquefied inert gases*
- *VdS 2381 Planning and installation of fire extinguishing systems using halocarbon gases*
- *VdS 2496 Guidelines for the triggering of fire extinguishing systems*
- *VdS 2498 Guidelines for fine water spray systems, supplementing VdS 2109*
- *VdS 2562 Procedure for the approval of new extinguishing techniques*

Fire detection, alarm, alarm control, triggering of a fire extinguishing system and its monitoring is usually done by a fire detection system approved for this purpose (see paragraph 5.2.1).

Fire extinguisher

In order to fight initial fires it is necessary to provide a sufficient number of appropriate and operational fire extinguishers. They should be available in all rooms in which a fire may occur, amongst others in the nacelle, in the tower base and in the electric power substation which might be arranged externally.

The extinguishing agent is to be adjusted to the existing fire loads. Due to the negative impacts of extinguishing powder on electrical and electronic equipment it is recommended to refrain from using powder extinguishers if possible.

Extinguishing systems (extinguishing agents)	Gas extinguishing systems		Water extinguishing systems				Other extinguishing systems	
	CO ₂ (high pressure)	Inert gases	Sprinkler	Water spray	Fine spray	Foam	Powder	Aerosol ¹⁾
Room/Installation wind turbine								
Room protection, e.g.,								
Nacelle with generator, transformer, hydraulic systems, gearbox, brake, azimuth drive	+	+	+	+	+	-	-	-
Hub with pitch drive and generator, if applicable	+	+	+	+	+	-	-	-
Raised floors with oil sump and cable and electrical installations	+	-	+	+	+	+	-	-
Central electric power substation, switchgear rooms (without transformer)	+	+	-	-	+	-	-	-
Tower base/platform with available installations, if applicable	+	+	+	+	+	-	-	-
Installation protection, e.g.,								
Control, inverter, switchgear cabinets (LV/MV), closed	+	+	-	-	+	-	-	-
Transformer	+	-	-	+	+	-	-	-
Control, inverter, switchgear cabinets (LV/MV), open	+	-	-	-	+	-	-	-
Hydraulic system, open	+	-	+	+	+	+	-	-
+ basically suitable - not likely suitable								
The data in this table refers to the basic suitability of several fire extinguishing systems with respect to their functionality and general application conditions in the respective area of the wind turbine's system; it serves as a first orientation guide and does not replace the required proof of suitability as well as the object-specific technical planning by appropriate specialist planners, e.g., VdS-approved installers. Type-specific characteristics of wind turbines and fire extinguishing systems have to be taken into account after consulting with the insurer (e.g., Engineering department), VdS Schadenverhütung GmbH (VdS loss prevention) as well as the certifying body for wind turbines, if applicable (for more information see also VdS guidelines for the planning and installation of the respective fire extinguishing systems).								
¹⁾ There is currently no empirical information available on the reliability and effectiveness concerning the application of aerosol extinguishing systems								

Table 4: Information on the selection of fire extinguishing systems for room and installation protection

At least one 6 kg CO₂ fire extinguisher and one 9 l foam fire extinguisher should be installed in the nacelle (pay attention to the risk of frost). And at least one 6 kg CO₂ fire extinguisher should be installed at the intermediate levels and at the tower base in the area of the electrical installations each.

Fire extinguishers have to be inspected by an expert at regular intervals, at least every two years. In case the extinguisher is subject to high stress,

e.g., due to environmental impacts, shorter time intervals might be required.

5.2.3 Fault monitoring

Fire detection systems and fire extinguishing systems have to be monitored constantly in order to ensure their operational reliability.

Failures with traditional fire protection systems, e.g., failure of individual fire detectors or leakage at the extinguishing agent stock or shrinkage of

the extinguishing agent supply, will be displayed directly at the fire protection system by means of an error message. Due to the operation without on-site staff and the remote location of wind turbines and the resulting non-identification of possible failures at the fire protection system on site, forwarding of all error messages to a permanently manned post (control post) is required. This control post will then initiate immediate recovery of the unlimited operational readiness of the fire protection system.

Any events have to be documented in the report book.

5.2.4 Deactivation of safety installations

Fire protection systems may only be deactivated for a short period of time after consulting with the persons in charge in case of compelling requirements. When deactivating a fire protection system it must always be checked whether there is any obligation to inform the non-life insurer (increase of risk in terms of the German Insurance Contract Act (VVG)).

Sufficient backup measures should be provided for the duration of the deactivation, e.g.,

- ensuring fire alarm/call,
- providing suitable fire fighting equipment (see also paragraph 5.2.2).

After completion of the work all safety and fire protection installations that had been deactivated have to be set in operation again. The operating condition of the systems should be visible at the entrance area of the wind turbine and at the primary control unit.

5.3 Measures for limiting loss

Experience has shown that it is sensible to prepare an emergency plan for the case of fire. This plan should include the following specifications, in particular:

- Determination of the personnel that is on standby in the internal work schedule for the existing wind turbines (ensuring “twenty-four-seven” standby of the control post)
- Preparation and introduction of an internal, written schedule in case of fire in which any immediate measures to be taken by the employee in charge are included. The schedule should include the following issues:

- Provision of local emergency telephone code
- Notification of fire brigade and police
- On-site support by fire brigade and police
- Shutdown of the wind turbine and disconnection from the power supply system, if required
- Report fire damage immediately to the insurer
- Preparation of an emergency concept for the case of fire after consulting with fire brigades and police offices in charge and with the insurer, if applicable. The following issues should be included in an emergency concept:
 - Leave internal standby schedule and a respective standby telephone number with the police and fire brigade
 - Information and briefing, if applicable, of the competent rescue forces (fire brigade, police) on:
 - Structure of the wind turbine
 - High-voltage components and combustible materials within the wind turbine
 - Route description and access to the wind turbine
 - Specification of immediate measures that have to be taken in case of a fire alarm/call, e.g., disconnection of the wind turbine from the power supply system
 - Information on the preparation of an emergency concept in case of fire for each wind turbine, e.g., appropriate emergency vehicles and necessary protective clothing as well as protection zone around the wind turbine affected

The following information should be easily accessible by everyone at the wind turbine:

- Identification number and emergency telephone number
- Code of conduct in case of fire at the wind turbine, e.g., notification of the fire brigade and seeking shelter as well as observing other safety instructions

With respect to offshore wind farms alternative or supplementary measures might be required for emergency planning due to special conditions.

5.4 Quality assurance

Experience has shown that the functions of technical installations, of safety-related installations, in particular, can be ensured for their period of operation or service life if appropriate measures for the purpose of quality assurance have been

taken with respect to planning, execution, and operation. This includes, amongst others:

- Generally accepted standards of technology as fundamentals of planning
- Application of products and systems with proven quality, which might be subject to internal controls and external monitoring, if applicable
- Qualification of specialist planners and execution experts. The following institutions/persons are considered sufficiently qualified: e.g., VdS-approved installer companies, VdS-approved experts for lightning and surge protection and EMC experts
- Acceptance inspection and recurring inspections by approved experts, e.g., VdS experts for fire protection systems
- Regular and proper maintenance by specialist companies and trained in-house specialized staff, respectively
- Documentation and monitoring of the maintenance to be performed

These measures may also be considered and reviewed in the course of type testing or certification of the wind turbine by independent and approved bodies.

When constructing a wind turbine, several aspects have to be considered in addition to structural design (statics) and revenue calculation, e.g., lightning and fire protection, electromagnetic interferences, noise immission, shadow impact, or impacts for the aviation business, fauna and natural scenery and view of a place. Accordingly, appropriate specialist planners should be consulted.

Reference: DIN VDE 0100-610 (VDE 0100-610) Erection of low-voltage installations – Part 6-61: Verification – Initial verification

For the purpose of erecting and maintaining wind turbines specialist companies should be assigned which dispose of

- the required specialist knowledge and experience,
- specialized staff,
- equipment and devices,

which can be proven by adequate references. In case of fire protection systems this can be ensured by VdS-approval of the installer companies, for example.

6 Literature/Sources

Act on granting priority to renewable energy sources (Renewable Energy Sources Act (*Erneuerbare-Energien-Gesetz, EEG*), 21st July 2004) <http://www.erneuerbare-energien.de/inhalt/>

Accident prevention regulation: Electrical installations and equipment (BGI A 3, formerly VBG 4)

Guideline for wind turbines; loads and strength analysis for tower and foundation, German Institute for Civil Engineering (*Deutsches Institut für Bautechnik, DIBt*), March 2004

DIN EN 50110-2 (VDE 0105-2) Operation of electrical installations

DIN EN 50308 (VDE 0127-100) Wind turbines – Protective measures – Requirements for design, operation and maintenance

DIN EN 60204-1 (VDE 0113-1) Safety of machinery – Electrical equipment of machines – Part 1: General requirements

DIN EN 61400-2 (VDE 0127-2) Wind turbine generator systems

DIN EN 60599 (VDE 0370-7, ICE 60599) Mineral oil-impregnated electrical equipment in service – Guide to the interpretation of dissolved and free gases analysis

DIN EN 61400-1; VDE 0127-1: Wind turbine generator systems

Part 1: Design requirement (IEC 61400-1)

Part 2: Safety of small wind turbines (IEC 61400-2)

DIN EN 62305 (VDE 0185-305) Protection against lightning

Part 1: General principles (DIN EN 62305-1; VDE 0185-305-1)

Part 2: Risk management (VDE 0185-305-2) supplement 1: Lightning threat in Germany, and supplement 2: Calculation guide for the assessment of the risk of physical damage to structures

Part 3: Physical damage to structures and life hazard (DIN EN 62305-3 and VDE 0185-305-3) with supplement 1: Additional information on the application of DIN EN 62305-3 and supplement 2: Additional information on special structures and supplement 3: Additional information on the

testing and maintenance of lightning protection systems

Part 4: Electrical and electronic systems within structures (DIN EN 62305-4, VDE 0185-305-4 and IEC 62305-4)

DIN VDE 0100-610 (VDE 0100-610) Erection of low-voltage installations - Part 6-61: Verification – Initial verification

Reference source: Beuth Verlag GmbH, Burggrafenstrasse 6, 10787 Berlin, www.beuth.de

GDV brochure „*Erneuerbare Energien: Gesamtüberblick über den technologischen Entwicklungsstand und das technische Gefährdungspotential*“; final report of the working group “Renewable Energies” of technical insurers within the GDV (German Insurance Association)

VdS 2008: Work involving fire hazards – Guidelines for fire protection

VdS 2010: Risk-oriented lightning and surge protection, Guidelines for loss prevention

VdS 2025: Cable and line systems, guidelines for loss prevention

VdS 2036: Permit for welding, cutting, soldering, thawing and abrasive cutting (sample)

VdS 2046: Safety regulations for electrical installations up to 1000 volt

VdS 2047: Safety regulations for work involving fire hazards

VdS 2093: Guidelines for CO₂ fire extinguishing systems; planning and installation

VdS 2095: Guidelines for automatic fire detection and fire alarm systems; planning and installation

VdS 2108: Guidelines for foam extinguishing systems; planning and installation

VdS 2109: Guidelines for water spray systems; planning and installation

VdS 2304: Application protection for electrical and electronic equipment; guidelines for planning and installation

VdS 2349: Electrical installations with minimal interferences

VdS 2380: Planning and installation of fire extinguishing systems using non-liquefied inert gases

VdS 2381: Planning and installation of fire extinguishing systems using halocarbon gases

VdS 2496: Guidelines for the triggering of fire extinguishing systems

VdS 2498: Guidelines for fine spray extinguishing systems supplementing VdS 2109

VdS 2562: Procedure for the approval of new extinguishing techniques

VdS 2858: Thermography in electrical installations

VdS 2861: VdS-approved experts for electric thermography (see also www.vds.de)

VdS 2871: Inspection guidelines according to clause 3602, guidelines for inspecting electrical installations

VdS 3432: VdS-approved experts for lightning and surge protection as well as EMC-suitable electrical installations (EMC experts)

Reference source: VdS Schadenverhütung Verlag, Cologne, www.vds.de

GL-Richtlinie für die Zertifizierung von Windenergieanlagen, Ausgabe 2003 mit Ergänzung 2004

GL Guideline for the Certification of Wind Turbines, Edition 2003 with Supplement 2004

GL Guideline for the Certification of Offshore Wind Turbines, Edition 2005

GL-Richtlinie für die Zertifizierung von Condition Monitoring Systemen für Windenergieanlagen, Ausgabe 2007

GL Guideline for the Certification of Condition Monitoring Systems for Wind Turbines, Edition 2007

GL-Wind-Leitfaden, Zertifizierung von Brandschutzsystemen für Windenergieanlagen (WEA), Prüfverfahren, Germanischer Lloyd (GL Wind Guideline, Certification of fire protection systems for wind turbines, test procedure)

Reference source: Germanischer Lloyd Industrial Services GmbH, Geschäftsbereich Windenergie, Steinhöft 9, 20459 Hamburg, www.gl-group.com/glwind

German WindEnergy Association (BWE)

Market Survey 2006

Working guideline “*Überprüfung des Zustandes des Blitzschutzsystems von Windenergieanlagen*”, 2004 (Inspection of the condition of wind turbines’ lightning protection systems)

Reference: <http://www.wind-energie.de/de/shop/bwe-marktuebersicht/marktuebersicht-2006/>

